

IMPACT ARENA™

FACILITY GUIDE





11,464 Seats Standard Capacity Floor Plan

ZONE	LEVEL 4–5 SEATS	ZONE	LEVEL 3 SEATS	ZONE	LEVEL 1 SEATS
A	336	SB	160		3,454
B	297	SC	160		
C	297	SD	160		
D	297	SE	191		
E	306	SF	160		
F	258	SG	136		
G	256	SH	152		
H	276	SI	136		
I	276	SJ	160		
J	264	SK	191		
K	198	SL	160		
L	264	SM	160		
M	276	SN	160		
N	276	2,086			
O	256				
P	258	VIP ROOM 1–25 522		THEATRE FLAT FLOOR FULL 3,454	
Q	306				
R	297				
S	297				
T	297				
U	336				
TOTAL	5,924			3,454	
TOAL 11,464 SEATS					

8,010 Seats Standard Capacity Floor Plan

ZONE	LEVEL 4–5 SEATS	ZONE	LEVEL 3 SEATS	ZONE	LEVEL 1
A	336	SB	160		
B	297	SC	160		
C	297	SD	160		
D	297	SE	191		
E	306	SF	160		
F	258	SG	136		
G	256	SH	152		
H	276	SI	136		
I	276	SJ	160		
J	264	SK	191		
K	198	SL	160		
L	264	SM	160		
M	276	SN	160		
N	276	2,086			
O	256				
P	258	VIP ROOM 1–25 522			
Q	306				
R	297				
S	297				
T	297				
U	336				
TOTAL	5,924				
TOAL 8,010 SEATS					

IMPACT ARENA
General and Technical Specification

Dimension	73.70 x 49.70 x 34.00 / 18.00 – 21.00 m. (L x W x H)
Gross Useable Space Level 1, Flat Floor Level 1, Foyer Level 3, Foyer	 4,000 sq.m. (43,055.64 sq.ft.) 5,500 sq.m. (59,201.50 sq.ft.) 5,500 sq.m. (59,201.50 sq.ft.)
Floor Material	Concrete sealed material (hardened concrete)
Floor Loading Capacity Flat Floor Loading Area Foyer	 2,000 kg. / sq.m. 2,000 kg. / sq.m. 750 kg. / sq.m.
Ceiling Material	Rockwool insulation and exposed steel structure
Ceiling Loading Capacity Flat Floor Stage Area Other Area	 2,000 kg. / 24 sq.m. 2,000 kg. / 34 sq.m. 2,000 kg. / 40 sq.m.
Catwalk	2.00 m. in width, handrails are 1.10 m. in height on both sides
Freight Door	1 set at service area each measuring 8.00 x 4.80 m. (W x H), 26.24 x 15.74 ft. (W x H)
Entrance and Exit	L1: 16 double doors 1.90 x 2.00 m. (W x H), 6.23 x 6.56 ft. (W x H) L3: 16 double doors 1.90 x 2.00 m. (W x H), 6.23 x 6.56 ft. (W x H) L4: 24 double doors 2.00 x 2.00 m. (W x H), 6.56 x 6.56 ft. (W x H)
Restroom	19 For male, 22 for female, 2 for disabled persons and 41 private restrooms

IMPACT ARENA
Mechanical and Electrical Specification

Main Feeder	Energize high voltage 24 kilovolts 2 feeders (power distribution through meter 4,500 Amps 24,000 volts/feeder) by Metropolitan Electricity Authority
Electrical Loading	Dry-type transformers: 7,500 kilovolt-Amps (7.50 megavolt-Amps)
Generator	Capacity 2 x 1,250 kilovolt-Amps (2 x 2,000 Amps 3 phases) supply power to emergency light connected circuit through automatic transfer switch, supply 30% of light illuminance
Floor Pit	2 electrical units at back stage and control stage (each consists of 1 set 63 Amps 3 phases ,1 set 100 Amp 3 phases) 2 units of telephone outlet, each is 4/ C and 0.50 millimeter 2 units of cold water and drainage at back stage and control stage (each consists of control valve ø ½" and drain pipe ø 3
Air-Conditioning System	Water-cooled chilled water air conditioning system with maximum cooling capacity 1,000 tons of refrigeration
Compressed Air	Available for all booths upon request
Water Supply	Cold water tank 1,050 cubic meters (maximum of 1-day stand by) Pressure 40-60 pounds Direct connection available to all booths (typical booth layout)
Drainage Point	Direct connection available to all booths (typical booth layout)
Lighting system	Metal halide lamp 400 watts and metal halide lamp 1,000 watts, high bay type,par 300 watts, high bay type with 300 luxes average illuminance
Broadcasting and Communicatiom	Cat5E Cable With RJ-45 Modoular Jack Connected to data/voice equipment rack
Emergency system	Fire sprinkler system, fire hose cabinet, fire extinguisher and fire alarm bell with manual station
PA System	Paging and announcements system Emergency line support
Security	Surveillance system

Symbol


Fire Hydrant


Fire Department Connection


Pull Alarm


Elevator


Toilet


Male Toilet


Female Toilet


Fire Extinguisher & Fire Hose


Fire Extinguisher


Fire Exit


Staircase


Restuarant


Disabled Toilet

IMPACT ARENA™

IMPACT LIVE NATION COMPANY LIMITED

99 POPULAR ROAD, BAN MAI SUBDISTRICT,
PAK KRET DISTRICT, NONTHABURI 11120

FACILITY GUIDE